

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Dr. Kuldeep Singh Yadav

(Name of Officers with designation) from CMS PHED

inspected the S.M. PUBLIC SCHOOL, SIDHUL BYE PASS ROAD, SITARGANJ

(Name & Address of the school) on 07/04/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DLW&TML/475/SMP-01 dated 27/03/2026

of DLW&TML Jal Sansthan Collectorate (PHED Lab) certified that

the S.M. PUBLIC SCHOOL, SIDHUL BYE PASS ROAD, SITARGANJ, US NAGAR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: 

Name:

Designation: उप जिला चिकित्सा अधीक्षक

Name & Address of the Office / Department:

उपजिला चिकित्सालय
सितारगंज (ऊधम सिंह नगर)

To

S.M. PUBLIC SCHOOL
SIDHUL BYE PASS ROAD, SITARGANJ, US NAGAR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S.Nagar)**

TEST REPORT

Name and Address of Organization/ Customer	S.M.Public School Sidcul Bye Pass Road Sitarganj(U.S.Nagar)- 262405 Uttarakhand		
Reference Sample Identification	105/UJS/DLWQTML/2025-26	Reporting Date	27/03/2026
Sample Location	Sample 01, Water Cooler		
Product Description	Drinking Water	Sample Submitted by	Customer
Reference Sample Identification:	DLWQTML/UJS/SMP-01		
Duration of Analysis:	27/03/2026 to 28/03/2026		
Date and Time of Sample Received:	27/03/2026 & 2:35PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25 ⁰ C	IS 3025 (Part 11), 2022	7.35	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180 ⁰ C mg/L	IS 3025 (Part 16), 2023	225	500Max	2000Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.45	1Max	5Max
4.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	184	200Max	600Max
5.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	220	200Max	600Max
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2024	40	75Max	200Max
7.	Chloride, mg/L	IS 3025 (Part 32), 2025	11.99	250Max	1000Max
8.	Magnesium as Mg, mg/l	IS 3025 (Part 46), 2023	29.16	30Max	100Max
9.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 5	5Max	15Max
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
11.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
12.	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S.Nagar)**

TEST REPORT

Name and Address of Organization/ Customer	S.M.Public School Sidcul Bye Pass Road Sitarganj(U.S.Nagar)- 262405 Uttarakhand		
Test Report ID	105/UJS/DLWQTML/2025-26	Reporting Date	27/03/2026
		Sample Location	Sample 01, Water Cooler
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/SMP-01		
Duration of Analysis:	27/03/2026 to 28/03/2026		
Date and Time of Sample Received:	27/03/2026 & 2:35 PM		

S N	Parameters	Test Method	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
2	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
3	Sulphate,mg/L	UV Spectrophotometry Method	5.3	200	400
4	Nitrate,mg/L	UV Spectrophotometry Method	4.4	45	No Relaxation
5	Fluoride,mg/L	Spands Method	0.52	1	1.5

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar